

# Work Order - Backup or Blockage Call

## **Hull Wastewater**

## **Work Order Information**

Date: 12/15/2017 Type: Corrective Maintenance Status: In Process

Asset 22 - WW - Priority: Normal Reason: Dirt / Debris

sewers/pipes/force mains

## **Description of Issue**

**Description: 262 Atlantic ave MH surcharged** 

Notes: Charged MH 20928A blockage in line

#### **Actions Taken**

**Staff:** Eric Sutton

Service:

11:30am observed MH area wet, opened MH observed charged, notified Aram he called Rosano Davis to pump MH for any additional SSO activity. 12:00 Rosano arrived pumped MH several times observed grease and toilet paper departed 130 . 215 pm national water main arrived. Jetted 115' 3 times cleared line street flowing freely departed 330.

### **Photos**





This work order was created in doFORMS.